

# Municipal Council Tumsar Dist. Bhandara (Maharashtra)



Phone-STD No.07183-Off.234679

mail: co.mc.tumsar@gmail.com

NPT/F.V./199 /2024-25

Date: -08/05/2024

#### --: FIRE SAFETY CERTIFICATE :--

Certified that Principal of LOTUS INTERNATIONAL PUBLIC SCHOOL, At-Dongargaon, Tah. Mohadi, Dist. Bhandara comprised of Ground floor basement(s) and First Floor owned/occupied by Lotus International Public School, At-Dongargaon, run by Shri Dhanlaxmi Bahuddeshiya Sanstha, Bhandara, have completed with the fire prevention and fire safety requirements in rule of Maharashtra Fire Safety Regulation, 2006 and verified by me on Service dt. 08/05/2024 in the presence of Mrs. Swati Gavin, Principal Lotus International Public School, At-Dongargaon and that the have occupancy up to classes XII with effect from dt. 04/05/2024 to 03/05/2025 in accordance with rule & subject to compliance of specific condition.

- School has instructed to get all the fire safety equipments Inspected in every year i.e. January to December and get Form B from which has to be submitted mandatorily to the Municipal Council, Tumsar.
- 2) According to the Maharashtra Fire Prevention and Lifesaving install fire hydrant and sprinkler with alarm system.
- 3) Fire Extinguishers equipments BC (CO2) of 4.5 kg. Quantity 02 of numbers were installed and these are valid till 03/05/2025.
- 4) Fire Extinguishers equipments ABC (DCP) of 06 kg. Quantity 08 of numbers were installed and these are valid till 03/05/2025.
- 5) 4 Fire Bucket with Stand 1 Number and Safety Indication Board were Installed in building premises.

6) It is also certified that Fire Extinguishers Equipments are in good conditions to run the School.

(LN CHAWARE) In-charge Fire Officer, Municipal Council, Tumsar.

#### SACHIN G. BADWAIK

DFSET, DIS & DIPLOMA IN (FIRE SERVICE) Rajendra Nagar, Balaghat Road, Tumsar District.: Bhandara - 441912

09850318191,09420866771



## SAMIKSHA ENTERPRIZES

FIRE & SAFETY EQUIPMENTS SUPPLIERS & MAINTENANCE Ganj Akhada Complex, Ramkrishna Nagar, Tumsar District.: Bhandara (MH.)

MSME No.:- UNYAM-MH06-OOO3978 GeM Reg No.:- Y88M230007868851 GST No.:- 27ANVPB7787K1Z1

Ref. No. SET/CER/2035/2024-25

Date: 04/05/2024

## CERTIFICATE

This is to Certify that following Fire Extinguisher Equipment's Servicing, Refilling, Maintains, H.P. Tested To 17.5 KGF/CM2 AS Per IS: 2190 & Checked by me or in presence of me found working order on Good Condition.

Name of Party :-THE, PRINCIPAL, LOTUS INTERNATIONAL PUBLIC SCHOOL At.:- DONGARGAON, Tah.- MOHADI, District-BHANDARA [M.S.]

Run By: - President / Secretary, Shri Dhanlaxmi Bahuuddeshiya Sanstha, Bhandara, F - 5539 / [B]

Established Premises :-

EDUCATIONAL BUILDING

Sr. No.	Fire Extinguisher Equipment Type	Extinguisher Equipment Capacity	Qty. In Nos.	Inspection & Servicing Date	Next Due Date For Servicing, Testing&	Remark
1	ABC [DCP] BC [Co2]	06.00 Kg. 1.	08	04.05.2024	Refilling 03.05.2025	
3	Fire Bucket	_04.50 Kg. 09:00 Ltr.	02	04.05.2024	03.05.2025	
4	Indication Board	1Set	04	) and in the same of the same		
	1	Total	15	09/		

Remark:-

1] This Certified One Year Valid Dt.: 04. 05, 2024 To Dt. 03. 05. 2025

Emergency Call: Fire - 101, Ambulance -- 108, Police - 100 21



For- SAMIKSHA ENTERPRIZES

SACHIN GHANSHYAM BADWAIK

Digitally signed by SACHIN **GHANSHYAM BADWAIK** Date: 2024.05.05 15:27:39 +05'30'





















#### Translation of rubber stamp matter from Marathi to English

Mr. Vijay C. Pardhi a Panel Translator of Govt. of Maharashtra and Notary Public here by notaries the below mentioned rubber stamp translation from Marathi to English.

Stamp in Vernacular language

- 1) तहसिलदार मोहाडी
- 2) तहसिलदार यांचे कार्यालय मोहाडी
- 3) नगर परिषद तुमसर, जि. भंडारा
- 4) (Chemist/ Senior Geologist)
  उप. विभागीयप्रयोगशाळा, मोहाडी
  विरष्ठ भूवैज्ञानिक, कार्यालय
  भूसाचिव, भंडारा.

**English Translation** 

- 1) Tehsildar Mohadi
- 2) Tehsildar's Office Mohadi
- 3) Municipal Council Tumsar,

Dist. Bhandara

4) (Chemist/ Senior Geologist)

**Sub Divisional Laboratory Mohadi** 

Senior Geologist Office,

Land Secretary, Bhandara

CERTIFIED TO BE TRUE TRANSLATION



Mondfille -

VIJAY C. PARDHI

Advocate & Notary Shreeram Nagar, TUMSAR Tah. Tumsar, Dist. Bhandara NOTARIAL REG.
ENTRY NO. 1196
DATE: 16105 rory



